

# SENATE AMENDMENT NO. \_\_\_\_\_

Offered by \_\_\_\_\_ of \_\_\_\_\_

Amend SS/House Bill No. 2062, Page 91, Section 569.200, Line 5,

2 by inserting after all of said line the following:

3 "640.144. 1. All community water systems shall be  
4 required to create a valve inspection program that includes:

5 (1) Inspection of all valves every ten years;

6 (2) Scheduled repair or replacement of broken valves;

7 and

8 (3) Within five years of August 28, 2020,

9 identification of each shut-off valve location using a  
10 geographic information system or an alternative physical  
11 mapping system that accurately identifies the location of  
12 each valve.

13 2. All community water systems shall be required to  
14 create a hydrant inspection program that includes:

15 (1) [Annual] Scheduled testing of every hydrant in the  
16 community water system;

17 (2) Scheduled repair or replacement of broken hydrants;

18 (3) A plan to flush every hydrant and dead-end main;

19 (4) Maintenance of records of inspections, tests, and  
20 flushings for six years; and

21 (5) Within five years of August 28, 2020,

22 identification of each hydrant location using a geographic  
23 information system or an alternative physical mapping system  
24 that accurately identifies the location of each hydrant.

25 3. The provisions of this section shall not apply to  
26 any state parks, cities with a population of more than

27 thirty thousand inhabitants, a county with a charter form of  
28 government and with more than six hundred thousand but fewer  
29 than seven hundred thousand inhabitants, a county with a  
30 charter form of government and with more than nine hundred  
31 fifty thousand inhabitants, or a public service commission  
32 regulated utility with more than thirty thousand  
33 customers."; and

34 Further amend the title and enacting clause accordingly.